



ORIGINAL



0000093439

Project Development

50TP

101 Ash Street, HQ14A  
San Diego, CA 92101-3017

Tel: 619.696.4455

Fax: 619.696.2911

JRowley@SempraGeneration.com

RECEIVED

2009 JAN 30 P 4:37

AZ CORP COMMISSION  
DOCKET CONTROL

January 30, 2009

Mr. Ernest G. Johnson  
Director, Utilities Division  
Arizona Corporation Commission  
1200 W. Washington Street  
Phoenix, AZ 85007

Re: **Docket No. E-00000D-09-0020 – SEP-II Ten-Year Transmission Plan**

Dear Mr. Johnson,

Enclosed are an original and thirteen copies of a Ten-Year Transmission Plan filed on behalf of SEP-II, a wholly owned subsidiary of Sempra Generation. This plan is filed in accordance with the requirements of Arizona Revised Statutes Section 40-360.02. The plan includes one project, a new 230 kV generation-tie line and associated switchyard facilities proposed in conjunction with the Mesquite Solar project to be located 2½ miles west of the 500 kV Hassayampa Switchyard.

Please contact me at (619) 696-4455 if you have any questions regarding this filing or the status of our transmission plan.

Sincerely,

Joseph H. Rowley

cc: Docket Control  
Prem Bahl (ACC)

Arizona Corporation Commission

DOCKETED

JAN 30 2009

DOCKETED BY	nr
-------------	----


Sempra Generation on behalf of SEP-II  
**Ten-Year Transmission Plan**

The Ten-Year Transmission Plan of SEP-II includes one project. The project consists of a new 230 kV generation-tie line and associated switchyard facilities proposed in conjunction with the Mesquite Solar photovoltaic project to be located 2½ miles west of the 500 kV Hassayampa Switchyard. The overall length of the generation-tie line is approximately 4 miles, as shown on the attached route map provided as Figure 1.

The generation-tie line will originate at a new 230 kV switchyard to be located on the Mesquite Solar site. The line will extend to and terminate at an expansion of the existing 230 kV bus of the Mesquite Generating Station. The project also includes a new, second connection between this existing 230 kV bus and the adjacent 500 kV Hassayampa Switchyard. The new connection will make use of an existing, spare 230/500 kV transformer bank. A diagram of the generation-tie line and switchyard facilities is provided as Figure 2.



### Figure 1: 230 kV Generation-tie Line Route





SEP-II Facilities




Figure 2: Semptra Generation (SEP-II) Ten-Year Transmission Plan